American Society of Sanitary Engineering Seal (Certification) Program

Factory Audit Inspection Test for: Barrier Type Floor Drain Trap Seal Protection Devices

Tested under ASSE Standard 1072 • Revised: 2007 Factory Audit Inspection Test

Manufactu	rer:
Model No:	
	tification Markings:
Size:	
	ns (screwed, flanged, etc.):
	Initial weight of vessel A with 2.0 inches of water: lbs. Initial weight of vessel B with 2.0 inches of water and the fouling wire: lbs. Initial weight of vessel C with 2.0 inches of water: lbs. Was the temperature and humidity of the test environment maintained at 100.0°F ± 5.0°F (37°C ± 2.8°C) and 20% (±10%) relative humidity throughout the test? Yes No The test period was for hours Final weight of Vessel A: lbs
	Final weight of Vessel B: lbs
	Final weight of Vessel C: lbs Was the weight loss in vessel B greater than 10% of the weight loss of cylinder A? Yes No
	Was the weight loss in vessel C greater than 0.01 pounds? ☐ Yes ☐ No
	In compliance?
3.4	Opening Test How many ounces of water did it take to open the device and allow passage of water? ounces

3.9	Physical Test of Membrane Material Was the device tested to and in compliance with the following ASTM test methods:		
	D1149 for ozone resistance?	☐ Yes ☐ No	
	D471 for water absorption?	☐ Yes ☐ No	
	D543 for chemical reagents?	☐ Yes ☐ No	
	G53 for weather-o-meter?	☐ Yes ☐ No	
	D624 for split tear?	☐ Yes ☐ No	
	D2137 method A for non-brittle brittleness?	☐ Yes ☐ No	
TESTING AGE	ENCY:		
	FAX:		
TEST ENGINE	EER(S):		
	the evaluations are based on our best judgments d of the performance of the device on test.	s and that the test data recorded is an	
Signature of th	ne official of the agency:		
Title of the office	cial:	Date:	
	seal of the Registered Professional Engineer e laboratory evaluation:		
	Signature	Seal	